

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-1004:0106 Page 1 of 1

**CATEGORY:** 7300 -- MISC. DEVICE/CONTROL UNIT ACCESSORIES

**LISTEE:** AIR PRODUCTS AND CONTROLS INC, 1749 E HIGHWOOD, PONTIAC, MI 48340  
Contact: Richard Steele (248) 332-3900 Fax (248) 332-8807  
Email: rsteele@ap-c.com

**DESIGN:** Models MR-201/T, MR-204/T, MR-101/T, MR-104/T, MR-201/XT and MR-204/XT relay modules. These units are relay modules which provide single-pole, double throw contacts. Models MR-101/T, MR-201/T and MR-201/XT provide one set while Models MR-104/T, MR-204/T and MR-204/XT provide four sets of contacts. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 120 VAC, 18-35 VDC

**INSTALLATION:** In accordance with listee's printed installation instruction, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, electrical rating and UL label.

**APPROVAL:** Listed as relay modules for use with separately listed compatible fire alarm control units.

**NOTE:**

\*Rev. 05-28-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **July 01, 2010**

*Listing Expires* **June 30, 2011**

Authorized By: **FRANCIS MATEO**, Program Coordinator  
*Fire Engineering Division*