

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner  
MEA 73-92-E Vol. XVI  
Report of Material and Equipment Acceptance Division

Manufacturer - Air Products and Controls, Inc., 1749 East Highwood, Pontiac, Michigan 48340

Trade Name(s) - Air Products and Controls, Inc.

Product - Fire Alarm Equipment Relay Module, Model MR-201/C, MR-204/C.

Pertinent Code Section(s) - Subchapter 17 and Reference Standard RS 17.

Test(s) - U.L. 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report - File S3403, Project 85NK27071 issued February 10, 1986 and revised March 30, 1994.

Description - These devices are intended for general purpose relay switching and incorporate multiple voltage operation with an L.E.D. relay energized feature.

All models are listed by Underwriters Laboratories as Control Unit Accessories and are compatible with any control panel provided the voltages are within relay specifications.

MR-201/C - Single DPDT 10 AMP relay enclosure operates on 24 V.A.C./24 V.D.C./115 V.A.C./230 V.A.C.

MR-204/C - (4) Four position DPDT 10 AMP relay in enclosure operated on 24 V.A.C./24 V.D.C./115 V.A.C./230 V.A.C.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated May 11, 1995, F.P. Index # 9503106 & 9504108.

Recommendation - That the above units be accepted on conditions that all uses, configurations, locations and installations comply with the New York City Building Code, specifically Subchapter 17 and with Reference Standard RS 17-3, including the NFPA as appropriate, UL Listing, manufacturer's instructions, Fire Department Rules and the New York City Electrical Code.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance July 14, 1999  
Examined By Mark Jacoby