

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Richard C. Visconti, R.A., Acting Commissioner
MEA 73-92-E Vol. XXII
Report of Material and Equipment Acceptance Division

Manufacturer - Air Products and Controls, Inc., 1749 East Highwood, Pontiac, Michigan 48340
Trade Name(s) - Air Products and Controls, Inc.
Product - Relay Module, Model MR-101/CR, MR-201/CR.
Pertinent Code Section(s) - Reference Standard RS 17.
Prescribed Test(s) - Compliance with U.L. 864.
Laboratory - Underwriters Laboratories, Inc.
Test Report - File S3403, Project 85NK27071 dated February 10, 1986 and revised February 11, 1997, and U.L. letter dated January 26, 1998.
Description - These devices are intended for general purpose relay switching and incorporate multiple voltage operation with an L.E.D. relay energized feature.

All models are listed by Underwriters Laboratories as Control Unit Accessories and are compatible with any control panel provided the voltages are within relay specifications.

MR-101/CR - Single SPDT 10 AMP relay enclosure with a Red Plastic Cover operates on 24 V.A.C./24 V.D.C./114 V.A.C./230 V.A.C.

MR-201/CR - One position DPDT 10 AMP relay enclosure with a Red Plastic Cover operates on 24 V.A.C./24 V.D.C./114 V.A.C./230 V.A.C.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated February 6, 1998, F.P. Index # 9801036A.

Recommendation - That the above units be accepted on conditions that all uses, configurations, arrangements and functions, locations and installations comply with the New York City Building Code, specifically Subchapter 17 and with Reference Standards RS 17-3 through RS 17-3C, NFPA 72, UL 864 Standard, manufacturer's instructions, Fire Department Rules and the Electrical Code of the City of New York.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance July 14, 1999
Examined By Mark J. Kelly