

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 73-92-E Vol. XXIX

Report of Material and Equipment Acceptance Division

Manufacturer - Air Products and Controls, Inc.

Trade Name(s) - Air Products and Controls, Inc.

Product - Relay Modules, MR-601/C/R, MR-602/C/R, MR-604/C/R, MR-608/C/R, MR-701/C/R, MR-702/C/R, MR-704/C/R, MR-708/C/R, MR-801/C/R, MR-802/C/R, MR-804/C/R, MR-808/C/R.

Pertinent Code Section(s) - Reference Standard RS 17.

Prescribed Test(s) - Compliance with U.L. 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report - File S3403, Project 04NK03562, issued January 23, 2004. UL letter dated June 3, 2004.

Description - The devices covered by this report are relays that provide single-pole, double throw contacts. The listed relays modules come in 1, 2, 4, or 8 position configurations: each relay position contains a red LED indicating the relay coil is energized. The models may employ the suffix C/R denoting a red metal enclosure.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated June 17, 2004, F.P. Index #0406016.

Recommendation - That the above units be accepted on conditions that all uses, locations and installations comply with the New York City Building Code, specifically Subchapter 17 and with Reference Standards RS 17-3 through RS 17-3C, inclusive, as applicable, including the NFPA as appropriate, and UL listing, manufacturer's instructions, Fire Department Directives, and the New York City Electrical Code.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

Examined By

Signature
Signature