

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 73-92-E Vol. XXVIII

Report of Material and Equipment Acceptance Division

Manufacturer - Air Products and Controls, Inc.

Trade Name(s) - Air Products and Controls, Inc.

Product - Relay Modules, MR-199X-13C/R, MR-199X-14/C/R.

Pertinent Code Section(s) - Reference Standard RS 17, Subchapter 17.

Prescribed Test(s) - U.L. 864.

Laboratory - Underwriters Laboratories, Inc.

Test Report - File S3403, Project 03NK24270, issued November 7, 2003, revised December 16, 2003. UL letter dated January 14, 2004.

Description - These devices are relays that provide double-pole, double throw contacts. The modules can be sold separately (just the relay without the enclosure - (receives UL Recognition) or with an enclosure (receives a UL listing). The models may employ the suffix C or C/R. Suffix C denotes a gray metal enclosure; suffix C/R/ denotes a red metal enclosure. No suffix denotes that it is shipped without an enclosure.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated February 26, 2004, F.P. Index #0401047.

Recommendation - That the above units be accepted on conditions that all uses, locations and installations comply with the New York City Building Code, specifically Subchapter 17 and with Reference Standards RS 17-3 through RS 17-3C, inclusive, as applicable, including the NFPA as appropriate, and UL listing, manufacturer's instructions, Fire Department Directives, and the New York City Electrical Code.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

June 21, 2004

Examined By

