

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 73-92-E Vol. XXX

Report of Material and Equipment Acceptance Division

Manufacturer - Air Products and Controls, Inc.

Trade Name(s) - Air Products and Controls, Inc.

Product - Fuse Modules: SC-111, SC-112, SC-114, SC-118; Suffixes /T, /S, or /C/R. Diode Modules: SC-201, SC-202, SC-204, SC-208; Suffixes /T, /S, or /C/R. Relay Modules: MR-311, MR-312, MR-313, MR-321, MR-322, MR-323; Suffixes /T, /S, or /C/R.

Pertinent Code Section(s) - Reference Standard RS 17.

Prescribed Test(s) - Compliance with UL 864, UL 916, UL 2017.

Laboratory - Underwriters Laboratories, Inc.

Test Report - File S3403, Project 03NK32896, issued March 24, 2004.

Description - SC-110 Series Fuse Modules provide two fuse circuits per module; sold in banks of 1, 2, 3, or 4 modules. SC-200 Series Diode Modules provide three diode circuits per module; sold in banks of 1, 2, 3, or 4 modules MR-310 Series Relay Modules provide single pole/double throw contacts and MR-320 Series Relay Modules provide double pole/double throw contacts; sold in banks of 1, 2, or 3 modules. All modules may employ Suffix /T, /S, or /C/R. Suffix /T denotes track mounted, suffix /S denotes spacer mounted, Suffix /C/R denotes a red steel enclosure.

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections letter dated July 28, 2004, F.P. Index #0407023.

Recommendation - That the above units be accepted on conditions that:

1. All above referenced products shall be provided with steel red enclosure.
2. All uses, configurations, arrangements and functions, applications and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17, and Reference Standards RS 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72, and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance *[Signature]* 2004

Examined By *[Signature]*