

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1004:119 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Air Products & Controls Inc., 1749 East Highwood, Pontiac, MI 48340
Contact: Richard Steele (248) 332-3900 FAX (248) 332-8807

DESIGN: Models MSR-50RM/W, MSR-50RM/R, MSR-50RM/S, MSR-50RMS/W/C, MSR-50RMS/W/O, MSR-50RMS/R/C, MSR-50RMS/R/O, MSR-50RMS/S/C, MSR-50RMS/S/O, MSR-50RK/W, MSR-50RK/R, MSR-50RK/S, MSR-50RKS/W/C, MSR-50RKS/W/O, MSR-50RKS/R/C, MSR-50RKS/R/O, MSR-50RKS/S/C, and MSR-50RKS/S/O smoke-automatic fire detector accessories. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, electrical rating and UL label.

APPROVAL: Listed as smoke detectors accessories for use with listee's separately listed compatible RW Series, SM-501 Series, SL-2000 Series, 2650-560, and 2650-561 duct smoke detectors to provide audible and visual indication as well as remote test/reset functions..

10-29-2007 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 24, 2009**

*Listing Expires **June 30, 2010***

Authorized By: **FRANCIS MATEO, Program Coordinator**
Fire Engineering Division